# MT300D-12VDC

# **Magnetic Dimmable**


Outdoor Black Powder Coated Steel Enclosure

Single Circuit: **12VDC**Total Wattage: **300W max**Input Voltage: **120V 60Hz** 





Conforms to UL STD. 2108 Certified to CSA STD. C22.2 № 250.0 model EM300



# INPUT Black OUTPUT Red + 120V 60Hz White 12VAC Purple -

#### Transformer

Dimmable with any LV magnetic dimmer as long as you cover dimmer's min load.

Temperature class B(130°C)

Two section bobbin completely separated primary and secondary windings Input leads are 18AWG 600V

Output leads are 12AWG 300V

Leads max. operational temperature is 105°C

Thermal manually reset primary breaker 5A

Magnetic manually reset secondary breaker 25A

#### Housing

The actual transformer 300W is encapsulated in the enclosure The enclosure is Black Powder Coated Steel, NEMA 3R rated Wiring compartment has 6 knockouts sizes for 3/8 inch screw cable connectors

Enclosure Temperature does not exceed 75°C at 45°C ambient and fully loaded

Dimensions (inch): H = 8, W = 4.1, D = 3.24

Weight (LBs): 9

## **Electrical Parameters**


Input Voltage:	120V 60Hz
Max. input current at full load:	3A
Output voltage without load:	12.7VDC
Output voltage fully loaded:	11.5VDC
Max. Total Wattage:	300W
Max. Output Current:	25A
Efficiency:	93%

# MT300D-12VDC

### **Magnetic Dimmable**

Outdoor Black Powder Coated Steel Enclosure

Single Circuit: **12VDC**Total Wattage: **300W max**Input Voltage: **120V 60Hz** 







Conforms to UL STD. 2108 Certified to CSA STD. C22.2 № 250.0 model EM300

#### **Installation Instruction**



- \* Read instruction completely before installation.
- \* Turn off electricity before wiring.
- \* Only qualified personal should install the unit
- \* Installation must comply with the NEC.
- \* Ensure the unit has input, output voltage and output wattage proper for your application.

#### Mounting

The transformer must be mounted in at least 15" of a free flow air space for proper ventilation.

The transformer must never be mounted next to or above heat radiated objects.

The maximum ambient temperature should not exceed 50 deg. C (110 deg. F)

Attach mounting plate to the rigid vertical surface with a two screws. Hang transformer on the hook of the mounting plate vertically when installed outdoor. When mounting indoor the unit can be installed horizontally, as well.

#### Connection

Open the wire compartment and remove knockouts for input and output, install strain reliefs (wire clamps). Use only right size and UL approved wire nuts.

### Input Connection

Bring your line and neutral wires through input strain relief and connect them to the Black and White transformers leads.

#### **Output Connection**

Bring your lights wires through output strain relief and connect to the Red + and Purple - transformer leads. Make sure all your connection very tight

## Grounding

The core and coil assemblies are grounded to the enclosure. The enclosure in turn should be grounded in accordance with NEC and local code. Connect the transformer green wire to the ground.