MT35D-12VDC

Class 2 Magnetic Dimmable

Outdoor Black Powder Coated Steel Enclosure

Single Circuit: 12VDC


Total Wattage: 35W max


Input Voltage: 120V 60Hz





Conforms to UL STD. 1310 Certified to CSA STD. C22.2 № 223 model EM35





Transformer

Dimmable with any LV magnetic dimmer as long as you cover dimmer's min load. Temperature class B(130°C) Input leads are 18AWG 600V Output leads are 18AWG 300V Leads max. operational temperature is 105°C Thermal self reset primary breaker 0.8A Thermal self reset secondary breaker 5A

Housing

The actual transformer 35W is encapsulated in the enclosure The enclosure is Black Powder Coated Steel, NEMA 3R rated Wiring compartment has 2 knockouts sizes for 3/8 inch screw cable connectors

Enclosure Temperature does not exceed 65°C at 45°C ambient and fully loaded

Dimensions (inch): H = 7, W = 2.11, D = 1.54Weight (LBs): 0.1

Electrical Parameters

120V 60Hz
0.36A
13.2VDC
11.6VDC
35W
2.9A
85%
13%

MT35D-12VDC

Class 2 Magnetic Dimmable

Outdoor Black Powder Coated Steel Enclosure

Single Circuit: **12VDC**

Total Wattage: 35W max


Input Voltage: 120V 60Hz






Conforms to UL STD. 1310 Certified to CSA STD. C22.2 № 223 model EM35

Installation Instruction





Mounting

The transformer must be mounted in at least 15" of a free flow air space for proper ventilation.

The transformer must never be mounted next to or above heat radiated objects. The maximum ambient temperature should not exceed 50 deg. C (110 deg. F) Attach mounting plate to the rigid vertical surface with a two screws. Hang transformer on the hook of the mounting plate vertically when installed outdoor. When mounting indoor the unit can be installed horizontally or horizontally- upside-down by using the third hole on the bottom.

Connection

Open the wire compartment and remove knockouts for input and output, install strain reliefs (wire clamps). Use only right size and UL approved wire nuts.

Input Connection

Bring your line and neutral wires through input strain relief and connect them to the Black and White transformers leads.

Output Connection

Bring your lights wires through output strain relief and connect to the Red + and Purple - transformer leads. <u>Make sure all your connection very tight</u>

Grounding

The core and coil assemblies are grounded to the enclosure. The enclosure in turn should be grounded in accordance with NEC and local code. Connect the transformer green wire to the ground.

MT35D-24VDC

Class 2 Magnetic Dimmable

Outdoor Black Powder Coated Steel Enclosure

Single Circuit: 24VDC


Total Wattage: 35W max


Input Voltage: 120V 60Hz





Conforms to UL STD. 1310 Certified to CSA STD. C22.2 № 223 model EM35





Transformer

Dimmable with any LV magnetic dimmer as long as you cover dimmer's min load. Temperature class B(130°C) Input leads are 18AWG 600V Output leads are 18AWG 300V Leads max. operational temperature is 105°C Thermal self reset primary breaker 0.8A Thermal self reset secondary breaker 3A

Housing

The actual transformer 35W is encapsulated in the enclosure The enclosure is Black Powder Coated Steel, NEMA 3R rated Wiring compartment has 3 knockouts sizes for 3/8 inch screw cable connectors

Enclosure Temperature does not exceed 75°C at 45°C ambient and fully loaded

Dimensions (inch): H = 7, W = 2.11, D = 1.54Weight (LBs): 0.1

Electrical Parameters

Input Voltage:	120V 60Hz
Max. input current at full load:	0.35A
Output voltage without load:	26.2VDC
Output voltage fully loaded:	23.6VDC
Max. Total Wattage:	35W
Max. Output Current:	1.7A
Efficiency:	

MT35D-24VDC


Class 2 Magnetic Dimmable

Outdoor Black Powder Coated Steel Enclosure

Single Circuit: **24VDC**

Total Wattage: 35W max

Input Voltage: 120V 60Hz








Conforms to UL STD. 1310 Certified to CSA STD. C22.2 № 223 model EM35

Installation Instruction



Mounting

The transformer must be mounted in at least 15" of a free flow air space for proper ventilation.

The transformer must never be mounted next to or above heat radiated objects. The maximum ambient temperature should not exceed 50 deg. C (110 deg. F) Attach mounting plate to the rigid vertical surface with a two screws. Hang transformer on the hook of the mounting plate vertically when installed outdoor. When mounting indoor the unit can be installed horizontally or horizontally- upside-down by using the third hole on the bottom.

Connection

Open the wire compartment and remove knockouts for input and output, install strain reliefs (wire clamps). Use only right size and UL approved wire nuts.

Input Connection

Bring your line and neutral wires through input strain relief and connect them to the Black and White transformers leads.

Output Connection

Bring your lights wires through output strain relief and connect to the Red + and Blue - transformer leads. <u>Make sure all your connection very tight</u>

Grounding

The core and coil assemblies are grounded to the enclosure. The enclosure in turn should be grounded in accordance with NEC and local code. Connect the transformer green wire to the ground.